

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER FAILURE TO MONITOR

**ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE  
ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.**

### Monitoring Requirements Not Met for Masontown Municipal Waterworks

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

*We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 1st Week in May 2019 \_\_\_\_\_ we did not complete all monitoring or testing \_\_\_\_\_ and therefore cannot be sure of the quality of our drinking water during that time.*

**What should I do?**

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for Total Chlorine Residual \_\_\_\_\_ and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Total Chlorine Residual	Weekly	0	4/28/19 through 5/4/19	Samples were not taken

**What happened? What was done?**

*The violation occurred because the required sample was not taken for the week of April 28, 2019. Weekly testing insures that the Total Residual Chlorine in the distribution system is maintained at a minimum 0.20 mg/L. The Total Residual Chlorine was sampled on April 23 & May 7, 2019 and found to be above the required 0.20 mg/L. The Masontown Municipal Waterworks is tested every week to verify that the minimum disinfectant residual concentration is maintained.*

For more information, please contact Robin Core, Borough Secretary \_\_\_\_\_ at (724) 583-7731 \_\_\_\_\_.

*Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This notice is being sent to you Masontown Municipal Waterworks \_\_\_\_\_.

PWS ID#: PA5260013 \_\_\_\_\_

Date distributed: 8/5/2019 \_\_\_\_\_